



City of Bellevue
Fire Department

The following format shall be used for all service labels:

DO NOT REMOVE

**By Order of the
Bellevue Fire
Department**

Year: _____ Month: _____ Next Due Date: _____

Firm: _____

Address: _____

Phone: _____ State of WA Contractor #: _____

Serviced by (Printed name): _____

Signature: _____ Date: _____

Description of work: _____



City of Bellevue
Fire Department

The following format shall be used for all service labels:

DO NOT REMOVE

**By Order of the
Bellevue Fire
Department**

Year: _____ Month: _____ Next Due Date: _____

Firm: _____

Address: _____

Phone: _____ State of WA Contractor #: _____

Serviced by (Printed name): _____

Signature: _____ Date: _____

Description of work: _____



City of Bellevue
Fire Department

The following format shall be used for all service labels:

DO NOT REMOVE

**By Order of the
Bellevue Fire
Department**

Year: _____ Month: _____ Next Due Date: _____

Firm: _____

Address: _____

Phone: _____ State of WA Contractor #: _____

Serviced by (Printed name): _____

Signature: _____ Date: _____

Description of work: _____

Requirements for Tagging Life Safety Systems and Reporting Test Results

Life safety systems shall be tagged as follows:

Red Tag – Systems out of service and/or whose operation are seriously impaired shall be tagged with a red service label by the building owner/manager or the Technician performing the certification and shall be immediately reported as an out of service system to the Bellevue Fire Department at (425) 452-2050 or impairmentnotification@bellevuewa.gov .

Yellow Tag – Systems that are functioning, but have deficiencies, shall be tagged with a yellow service label and the confidence testing report shall be faxed, mailed or delivered to the Fire Department within 15 days of the date of the test. Example: a fire alarm system with a “trouble” indication shall receive a yellow service label.

Green Tag – No Deficiencies – Systems with no deficiencies shall be tagged with a green service label and the confidence testing report shall be faxed, mailed or delivered for receipt by the Fire Department within 30 days of the test.

mac9213.3/09.indd

Requirements for Tagging Life Safety Systems and Reporting Test Results

Life safety systems shall be tagged as follows:

Red Tag – Systems out of service and/or whose operation are seriously impaired shall be tagged with a red service label by the building owner/manager or the Technician performing the certification and shall be immediately reported as an out of service system to the Bellevue Fire Department at (425) 452-2050 or impairmentnotification@bellevuewa.gov .

Yellow Tag – Systems that are functioning, but have deficiencies, shall be tagged with a yellow service label and the confidence testing report shall be faxed, mailed or delivered to the Fire Department within 15 days of the date of the test. Example: a fire alarm system with a “trouble” indication shall receive a yellow service label.

Green Tag – No Deficiencies – Systems with no deficiencies shall be tagged with a green service label and the confidence testing report shall be faxed, mailed or delivered for receipt by the Fire Department within 30 days of the test.

mac9213.3/09.indd

Requirements for Tagging Life Safety Systems and Reporting Test Results

Life safety systems shall be tagged as follows:

Red Tag – Systems out of service and/or whose operation are seriously impaired shall be tagged with a red service label by the building owner/manager or the Technician performing the certification and shall be immediately reported as an out of service system to the Bellevue Fire Department at (425) 452-2050 or impairmentnotification@bellevuewa.gov .

Yellow Tag – Systems that are functioning, but have deficiencies, shall be tagged with a yellow service label and the confidence testing report shall be faxed, mailed or delivered to the Fire Department within 15 days of the date of the test. Example: a fire alarm system with a “trouble” indication shall receive a yellow service label.

Green Tag – No Deficiencies – Systems with no deficiencies shall be tagged with a green service label and the confidence testing report shall be faxed, mailed or delivered for receipt by the Fire Department within 30 days of the test.

mac9213.3/09.indd